



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

June 25, 2018

CERTIFIED MAIL RECEIPT#: 7006276000038961900
RETURN RECEIPT REQUESTED

USA EPA Region 10
Attn: NPDES Permits Unit Manager
1200 Sixth Ave, STE 900
OWW-191
Seattle, WA 98101-3140

RE: Permit ID00206-3

Dear NPDES Permits Unit Manager,

On June 23, 2018, at 3:15 p.m., the City of Nampa Wastewater Collection Crew was notified by dispatch of possible sewer coming from a manhole at the 1100 block of 3rd Street South. Upon arrival, the crew found approximately 300 gallons of sewage was puddled in a corner of the roadway. The sewage was seeping slowly from a manhole.

The crew used the hydrocleaner to stop the overflow and began investigating the cause of the backup. The investigation revealed a blockage in the line that was caused from rocks and asphalt from the current resurfacing of the road. The blockage was cleared, and normal flow was resumed. On June 25, 2018, a follow-up inspection occurred with the CCTV to verify if the line is still clear from debris.

The overflow was contained and at no time did the overflow reach the waters of the US.

Thank you,


Andy Zimmerman
City of Nampa Wastewater Superintendent

NAMPA*Proud*



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

June 25, 2018

CERTIFIED MAIL RECEIPT#: 7006276000038961894
RETURN RECEIPT REQUESTED

USA EPA Region 10 Idaho Operations Office
Attn: Ms. Maria Lopez
950 W. Bannock Ste. 900
Boise, ID 83702

RE: Permit ID00206-3

Dear Ms. Lopez,

On June 23, 2018, at 3:15 p.m., the City of Nampa Wastewater Collection Crew was notified by dispatch of possible sewer coming from a manhole at the 1100 block of 3rd Street South. Upon arrival, the crew found approximately 300 gallons of sewage was puddled in a corner of the roadway. The sewage was seeping slowly from a manhole.

The crew used the hydrocleaner to stop the overflow and began investigating the cause of the backup. The investigation revealed a blockage in the line that was caused from rocks and asphalt from the current resurfacing of the road. The blockage was cleared, and normal flow was resumed. On June 25, 2018, a follow-up inspection occurred with the CCTV to verify if the line is still clear from debris.

The overflow was contained and at no time did the overflow reach the waters of the US.

Thank you,


Andy Zimmerman
City of Nampa Wastewater Superintendent

NAMPA*Proud*



Nampa Wastewater Division

340 W. Railroad Street, Nampa, Idaho 83687-1741
(208) 468-5840, FAX 467-9194

June 25, 2018

CERTIFIED MAIL RECEIPT#: 7006276000038961887
RETURN RECEIPT REQUESTED

Idaho Department of Environmental Quality
Attn: Mr. Todd Crutcher
1445 N. Orchard
Boise, ID 83706

RE: Permit ID00206-3

Dear Mr. Crutcher,

On June 23, 2018, at 3:15 p.m., the City of Nampa Wastewater Collection Crew was notified by dispatch of possible sewer coming from a manhole at the 1100 block of 3rd Street South. Upon arrival, the crew found approximately 300 gallons of sewage was puddled in a corner of the roadway. The sewage was seeping slowly from a manhole.

The crew used the hydrocleaner to stop the overflow and began investigating the cause of the backup. The investigation revealed a blockage in the line that was caused from rocks and asphalt from the current resurfacing of the road. The blockage was cleared, and normal flow was resumed. On June 25, 2018, a follow-up inspection occurred with the CCTV to verify if the line is still clear from debris.

The overflow was contained and at no time did the overflow reach the waters of the US.

Thank you,

A handwritten signature in blue ink, appearing to read "Andy Zimmerman".

Andy Zimmerman
City of Nampa Wastewater Superintendent

NAMPA*Proud*